

ISSUED FOR CONSTRUCTION - IMT @ Riata

Revisions Narrative

The Contract Documents should be used for definitive information regarding any revisions, however an over view of the changes includes the following:

ARCHITECTURAL

A0.01	Abbreviations - Key Notes - Materials & Symbols	Added note 52 on sealing tuck under garages from residential.
A0.51	Window Schedule	Deleted fire rated windows E & F. Made E a 2'-8" window and moved. Revised a few dimensions. Added a window type to match plans.
A0.60	Durability Checklist	Added some locations for information missing
A2.10	Clubhouse	Rekeyed a couple of doors and windows to coordinate with schedule. Added column wrap.
A2.20	Building 2 - Level 1	Eliminated walk-off mats. Eliminated fire rated windows. Pulled out Stair #1 to comply with Permit Comment on providing openness.
A2.21	Building 2 - Level 2	Eliminated fire-rated windows. Made E a 2'-8" window and moved. Pulled out Stair #1 to comply with Permit Comment on providing openness.
A2.22	Building 2 - Level 3	Eliminated fire-rated windows. Made E a 2'-8" window and moved. Pulled out Stair #1 to comply with Permit Comment on providing openness. Eliminated skylights
A2.23	Building 2 - Roof Plan	Pulled out Stair #1 to comply with Permit Comment on providing openness. Eliminated skylights
A2.30a	Building 3A - Level 1	Eliminated walk-off mats
A2.30b	Building 3B - Level 1	Eliminated walk-off mats
A2.32a	Building 3A - Level 3	Eliminated skylights
A2.32b	Building 3B - Level 3	Eliminated skylights
A2.33A	Building 3A - Roof Plan	Eliminated skylights
A2.33b	Building 3B - Roof Plan	Eliminated skylights
A2.40	Building 4 - Level 1	Eliminated walk-off mats Eliminated fire-rated windows. Made E a 2'-8" window and moved. Pulled out Stair #6 to comply with permit comment on providing openness.
A2.41	Building 4 - Level 2	Eliminated fire-rated windows. Made E a 2'-8" window and moved. Pulled out Stair #6 to comply with permit comment on providing openness.
A2.42	Building 4 - Level 3	Eliminated fire-rated windows. Made E a 2'-8" window and moved. Pulled out Stair #6 to comply with permit comment on providing openness. Eliminated skylights
A2.43	Building 4 - Roof Plan	Eliminated skylights
A2.43	Building 4 - Roof Plan	Pulled out Stair #6 to comply with permit comment on providing openness.
A2.50	Building 5 & 7 - Level 1	Eliminated walk-off mats Added slab fold for wheel stop in the garages.
A2.52	Building 5 & 7 - Level 3	Eliminated skylights
A2.53	Building 5 - Roof Plan	Eliminated skylights
A2.60	Building 6 & 8 - Level 1	Eliminated walk-off mats Added slab fold for wheel stop in the garages.
A2.62	Building 6 & 8 - Level 3	Eliminated skylights

A2.63	Building 6 - Roof Plan	Eliminated skylights
A2.70	Buildings 9-15 - Level 1-2	Eliminated skylights
A2.71	Building 16-17	Eliminated skylights
A2.72	Building 7-17 - Roof Plan	Eliminated skylights
A2.81	Detached Garage	Added slab fold for wheel stop and slope for drainage.
A2.82	Pool Pavillion	Modified Pool Pavillion to coordinate with Landscape drawings
A5.20	Building 2 - Elevations	Eliminated E & F fire rated windows from elevation
A5.40	Building 4 - Elevations	Eliminated E & F fire rated windows from elevation
A7.10	Roof details	Eliminated skylight detail
A7.30	Typical Balcony Railing Details	Revised railing details per our meeting on 4/24/2015
A7.31	Balcony Screen Details	Added note about top and bottom rail only with wire mesh behind perforated metal panel. Keyed details.
A8.02	Stair Tower	Eliminated walk-off mat
A8.04	Stair Tower	Modified stair to provide code required openness per permit comment