

## IMT Construction Document Revision Narrative

### Issue for Construction May 13, 2015

#### **S1.01**

Revised General section of General Notes.

Revised floor and roof loading in Prefabricated Wood Truss and Joist notes.

#### **S1.02**

New sheet – Added Structural “Leed Notes”.

#### **S1.03**

New sheet – Added Special Inspection Notes.

#### **S1.10d**

Revised slab edge dimensions per latest architectural background.

#### **S1.20d**

Revised slab edge dimensions per latest architectural background.

#### **S1.30ad**

Revised slab edge dimensions per latest architectural background.

#### **S1.30bd**

Revised slab edge dimensions per latest architectural background.

#### **S1.50d**

Revised slab edge dimensions per latest architectural background.

#### **S1.60d**

Revised slab edge dimensions per latest architectural background.

# Group Structural Engineers, Inc.

TBPE Firm # F-6452

## **S1.61d**

Revised slab edge dimensions per latest architectural background.

## **S1.70d**

Revised slab edge dimensions per latest architectural back ground.

## **S1.71d**

Revised slab edge dimensions per latest architectural background.

## **S1.80d**

Revised slab edge dimensions per latest architectural background.

## **S2.10**

Changed 10 slab marks and 13 beam marks around the lower left corner of the plan (Area of Grids K – 7 to 19).

## **S2.20**

Center line of piers on building 2 clarified.

Clarified around 10 beam marks towards the left of the plan.

Clarified around 6 slab marks towards the right and left of the plan.

Added 2 post to the bottom left of the plan.

Stair/Elevator: clarified 7 pier locations, clarified one B35 and added one B36 beam mark, added notes "Extend B36 reinforcing to the end of the cantilever".

Added column base information for 5 ½" X 5 ½" glulam column.

## **S2.21**

Revised typical bay framing sizes.

## **S2.22**

Revised typical bay framing sizes.

# Group Structural Engineers, Inc.

TBPE Firm # F-6452

## **S2.23**

Revised typical bay framing sizes.

## **S2.30a**

Center line of piers on building 3a clarified.

Added column base information for 5 ½" X 5 ½" glulam column.

## **S2.31a**

No Change

## **S2.32a**

No Change

## **S2.33a**

Clarified around 28 beam marks and around 2 slab marks towards the right and left of the plan.

## **S2.30b**

Center line of piers on building 3b clarified.

Clarified 10 beam marks and 4 slab marks towards the right of the plan.

Added column base information for 5 ½" X 5 ½" glulam column.

## **S2.31b**

No Change

## **S2.32b**

No Change

## **S2.33b**

No Change

## **S2.40**

# Group Structural Engineers, Inc.

TBPE Firm # F-6452

Center line of piers on building 4 clarified.

Clarified 2 slab marks towards the right of the plan and 1 slab mark to the left of the plan.

Clarified around 2 beam marks towards the left of the plan.

Added column base information for 5 ½" X 5 ½" glulam column.

Stair/Elevator: Modified one S3 to S1 and two S1 to S3 slab mark and one S2 to S1, clarified eight beam marks, added notes "Extend B36 reinforcing to the end of the cantilever" and clarified 3 pier locations.

## **S2.41**

Revised typical bay framing sizes.

## **S2.42**

Revised typical bay framing sizes.

## **S2.43**

Revised typical bay framing sizes.

## **S2.50**

Center line of piers on building 5 clarified.

Clarified around 17 slab marks on the plan.

Clarified around 49 beam marks on the plan.

Stair/Elevator: Added one S2 slab mark, Modified one S2 to S3 slab mark, clarified 7 pier locations, clarified one B35 and added one B36 beam mark, added notes "Extend B36 reinforcing to the end of the cantilever".

Added column base information for 5 ½" X 5 ½" glulam column.

## **S2.51**

Revised typical bay framing sizes.

## **S2.52**

Revised typical bay framing sizes.

## **S2.53**

Revised typical bay framing sizes.

## **S2.60**

Center line of piers on building 6 clarified.

Clarified 2 slab marks towards the right of the plan.

Clarified around 22 beam marks towards the left and right of the plan.

Added column base information for 5 ½" X 5 ½" glulam column.

## **S2.61**

Revised typical bay framing sizes.

## **S2.62**

Revised typical bay framing sizes.

## **S2.63**

Revised typical bay framing sizes.

## **S2.73**

No Change

## **S2.74**

No Change

## **S2.75**

No Change

## **S2.80**

No Change

## **S2.81**

# Group Structural Engineers, Inc.

TBPE Firm # F-6452

No Change

## **S2.82 (new sheet)**

Added New Pool Pavilion Foundation and Roof Framing Plans.

## **S3.01**

Added clarification notes to structural slab joint detail 12/S3.01.

## **S3.02**

Added Section 10/S3.02

Added Section 13/S3.02

Added Section 14/S3.02

Added Section 15/S3.02

## **S4.01**

Adjusted embed. depth on 01/S4.01 to 10".

## **S4.02**

No Change

## **S4.03**

No Change

## **S4.04**

No Change

## **S4.05**

No Change

## **S4.06**

No Change

## **S4.07**

# Group Structural Engineers, Inc.

TBPE Firm # F-6452

No Change

## **S4.08**

No Change

## **S4.09**

Deleted Section 06/S4.09

Added Section 07/S4.09

Added Section 08/S4.09

## **S5.01**

Added beam marks B24, B25, B26, B27, B28, B29 and B39 to the Concrete Beam Schedule.

Added clarification to beams B1, B2, B3, B7, B9, B10, B14, B15, B16, B20, B23.

## **S5.02**

Added new sheet and moved the Concrete Slab Schedule and notes to this new sheet.

Added Slab Marks CS15, CS16, CS17, CS18, CS19.